30,000 LITRE CONCRETE WATER HOLDING TANK MODEL H30L

CONSTRUCTION DETAILS: LOW PROFILE

Concrete: 35 MPa at 28 Days, 5 to 8% Air Entrainment.

Reinforcing: Designed for a maximum 1.2 metre burial over the top slab in firm soil.

Optional reinforcing for CHBDC vehicular loading available upon request.


WEIGHT: CAPACITY: - 21,100 kg Per Vertical Metre - 24,917 Ltires

Top Slab - 21,100 kg

Per Vertical Metre - 24,917 Ltires

Bottom Section - 31,500 kg

To Underside of Roof Slab - 30,150 Litres



500

7570

-8000

Note 4



WWW.WILKINSONHEAVYPRECAST.COM DUNDAS, ONTARIO 1-800-263-8503

NOTES:

- 1. Large 685 mm diameter roof access openings facilitate tank maintenance. Unless otherwise specified when ordered this tank will be shipped with 840 mm diameter concrete roof access cover only. Please see Access Riser section for available riser & hatch options.
- 2. Close tolerance joint and fibrous mastic sealant ensures a solid structural & watertight seal. Primer & Mastic Band are supplied with each tank for application to the external surface of the tank over the joint between sections. All sealant is to be applied by the installing contractor.
- 3. Flexible watertight inlet pipe connector to accommodate 150 mm diameter PVC pipe. Size and location of connectcions are customizable.
- 4. Top slab & bottom section lifting points four places.
- 5. Knockout suitable to accommodate a flexible, watertight pipe connectoin for 250, 275 or 300 mm diameter PVC pipe.
- 6.150mm dia galvanized steel pipe Cross Beam (Stainless Steel Optional).

Some Available Options:

- Aluminum ladder rungs to the floor. Consult with the factory as to how this will effect the size and location of the access opening.
- Mechanical connection of the tank sections to enhance water tightness and resistance to frost heave.

Precast Concrete Hatch
Cover with 13mm dia
steel handles
Tapered Plug
Note 1
1750
1210
1210



Note

Inlet@-

1275

1760

Inlet Invert

^L215

*Product designed for a **Maximum 1.2 Metre** burial over the top slab in firm soil away from any area of vehicular traffic.

Note 6

Dimensions in mm

For recommended installation proceedures refer to Wilkinson Installation Guidelines.

Note 5-

215-

-Note 2

440